

توضيحات الخاصة بمناقصة الطاقة الشمسية (PCBS-CFG/2020/004-SOLAR)

نرجو ان تؤخذ بعين الاعتبار الأمور التالية:

1. A European inverter is required and the monitoring system required according to the technical specifications attached to the contract not necessary VSN700.
2. According to the contract specifications and to facilitate the maintenance process its necessary install at circuit breaker instead of fuse.
3. Putting protections in the main board is one of the requirements for connecting projects with distribution companies so we have no objection to putting AC protection with coordinate to the JEDCO because it's their responsibility.

